

2023 Water Quality Report for City of Menominee

Water Supply Serial Number: 4250

This report covers the drinking water quality for the City of Menominee for the 2023 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2023. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

Your water comes from the bay of Green Bay. The State performed an assessment of our source water to determine the susceptibility of the relative potential of contamination. **The susceptibility rating is on a seven-tiered scale from “very-low” to “very-high” based on geologic sensitivity. The City of Menominee’s source water is categorized as Highly Susceptible, given land use and potential source of contamination, within the source water area.**

Significant sources of contamination include, Manufacturing facilities, Solid waste disposal sites, Agricultural operations, and Storage tanks.

If you would like to know more about this report, please contact: One of the individuals listed at the bottom of this report.

Contaminants and their presence in water: Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA’s Safe Drinking Water Hotline (800-426-4791).


Vulnerability of sub-populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their

health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Sources of drinking water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.



In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2023 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2023. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
- RL: Reporting limit
- N/A: Not applicable
- ND: not detectable at testing limit
- ppm: parts per million or milligrams per liter
- ppb: parts per billion or micrograms per liter
- ng/l: nanograms per liter or parts per trillion
- pCi/l: picocuries per liter (a measure of radioactivity)
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- Level 1 Assessment: A study of the water supply to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

1 Monitoring Data for Regulated Contaminants

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Fluoride (ppm)	4	4	0.66	0.44 to 0.87	2023	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium ¹ (ppm)	N/A	N/A	32.0	N/A	2023	No	Erosion of natural deposits
TTHM Total Trihalomethanes (ppb)	80	N/A	37.0	14.9 to 53.3	2023	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	19.0	9.8 to 37.3	2023	No	Byproduct of drinking water disinfection
Chlorine ² (ppm)	4	4	0.94	0.33 to 1.29	2023	No	Water additive used to control microbes
Total Organic Carbon (percent removal)	NA	TT	2.73	N/A	2023	No	Naturally present in the environment

¹ Sodium is not a regulated contaminant.

² The chlorine "Level Detected" was calculated using a running annual average.

Per- and polyfluoroalkyl substances (PFAS)							
Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ng/l)	370	N/A	ND	N/A	2023	No	Discharge and waste from industrial facilities utilizing the Gen X chemical process
Perfluorobutane sulfonic acid (PFBS) (ng/l)	420	N/A	ND	N/A	2023	No	Discharge and waste from industrial facilities; stain-resistant treatments
Perfluorohexane sulfonic acid (PFHxS) (ng/l)	51	N/A	ND	N/A	2023	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorohexanoic acid (PFHxA) ³ (ng/l)	400,000	N/A	18	ND to 18.0	2022 2023	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorononanoic acid (PFNA) (ng/l)	6	N/A	ND	N/A	2023	No	Discharge and waste from industrial facilities; breakdown of precursor compounds
Perfluorooctane sulfonic acid (PFOS) (ng/l)	16	N/A	ND	N/A	2023	No	Firefighting foam; discharge from electroplating facilities; discharge and waste from industrial facilities
Perfluorooctanoic acid (PFOA) ³ (ng/l)	8	N/A	1.98	ND to 1.98	2022 2023	No	Discharge and waste from industrial facilities; stain-resistant treatments
Inorganic Contaminant Subject to ALs	AL	MCLG	Your Water	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead ⁴ (ppb)	15	0	1.0	0.0 to 2.0	2023	0	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper ⁴ (ppm)	1.3	1.3	0.0	0 to 0.1	2023	0	Corrosion of household plumbing systems; Erosion of natural deposits

³Samples were collected during and after the 2022 KK Integrated Logistics Inc. fire. Subsequent samples have shown results are back to non-detectable levels, including results for 2023.

⁴Lead & Copper/Ninety (90) percent of the samples collected were at or below the level reported for our water.

Additional Monitoring

Unregulated contaminants are those for which the U.S. EPA has not established drinking water standards. Monitoring helps the U.S. EPA determine where certain contaminants occur and whether regulation of those contaminants is needed.

Unregulated Contaminant Name	Level Detected	Range	Year Sampled	Typical Sources of Contaminant
Perfluorobutanoic Acid (PFBA) (ng/l)	3.0	ND to 3.0	2023	Firefighting foam

Information about lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Menominee is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line, it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Our water supply has 608 lead service lines and 809 service lines of unknown material out of a total of 4,146 service lines.

Monitoring and Reporting to the Michigan Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the U.S. EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2023.

We will update this report annually and will keep you informed of any problems that may occur throughout the year as they happen. Copies are available at City Hall. This report will not be sent to you.

We invite public participation in decisions that affect drinking water quality. Your water/wastewater utility board meets on the second Thursday of each month at city hall at 4pm. For more information about your water or the contents of this report, see contacts below. For more information about safe drinking water, visit the U.S. EPA at <http://www.epa.gov/safewater>

Mike Borths
Lead Operator
Menominee Water Plant
1101 26th Ave.
Menominee, MI 49858
Office, 906-863-6744
Cell Ph. 906-290-3838

Mike Thorsen
Senior Project Manager
Menominee W&WW Utilities
P.O. Box 453
Menominee, MI 49858
Office, 906-863-3050
Cell Ph. 906-630-1016

Brett Botbyl
City Manager
City of Menominee
2511 10th Street
Menominee, MI 49858
906-863-2656